

9 1/4"

6" THICK CONC. SLAB ON GRADE. REINFORCE w/ #3@15"
O.C. PLACE SLAB ON A 10 MIL VAPOR BARRIER OVER 4" OF
GRANULAR MATERIAL ON SELECT FILL. SEE
GEOTECHNICAL REPORT FOR GRANULAR MATERIAL,
SELECT FILL AND COMPACTION REQUIREMENTS.

REFERENCE FINISH FLOOR EL. = +0'-0" = 269.00'